



City of Concord, New Hampshire

PURCHASING DEPARTMENT

CITY HALL, 41 GREEN STREET

CONCORD, NH 03301

(603) 225-8530

FAX: (603) 230-3656

August 11, 2008

ADDENDUM NUMBER ONE

RFP51-08

GRANULAR ACTIVATED CARBON FOR TASTE AND ODOR CONTROL WATER TREATMENT PLANT

TO ALL FIRMS OF RECORD: This addendum forms a part of and modifies the proposal and contract documents and technical specifications for the project named above. The following additions, changes and clarifications are made to the original proposal documents:

1. **Question:** Page 2 and page 20 call for a 5% bid bond. Page 18 calls for a 10% bid bond. Please confirm which is required.

Answer: A 10% bid bond is required for any proposal in excess of \$25,000.

2. **Question:** Page 10, Assignment Provision. Please clarify/interpret.

Answer: If, in restraint of trade, there is a violation of the anti-trust laws resulting in the City paying higher prices than it otherwise would, the successful vendor will assign to the City the right to recover the overcharges.

3. **Question:** Exhibit A, Parte 1.01 specifies that the existing media is GAC. Part 2.01 specifies that the existing media is anthracite. Please confirm if the existing media is GAC or anthracite.

Answer: The existing media is GAC.

4. **Question:** Please clarify whether the RFP requires 820 or 830 carbon.


Answer: The RFP specification should be for 820 carbon.

5. **Question:** Exhibit A, Part 2.01.F calls for scraping of the top 1” of GAC as part of the installation process. Can this requirement be removed from the specifications?

Answer: Please disregard this requirement.

PLEASE BE ADVISED THAT THE PROPOSER MUST ACKNOWLEDGE RECEIPT OF ADDENDUM ONE ON THE PROPOSAL SHEET SIGNATURE PAGE.

CITY OF CONCORD, NEW HAMPSHIRE



DOUGLAS B. ROSS
PURCHASING AGENT